Kimley»Horn

June 2, 2022

Camryn Siverson
Environmental Planner
Lee County Development Services
1500 Monroe Street
Fort Myers, FL 33901

RE: *Response to Insufficiency Comments*
Project Name: TCW McGregor Blvd
Application/Petition No.: ADD2022-00007

Kimley Horn Reference No.: 013726010

Dear Ms. Siverson,

We are in receipt of your letter dated June 1, 2022 in which questions and additional information was requested on the above referenced project. The following are your comments in followed by our responses in **bold**:

Solid Waste:

1. The proposed dumpster enclosure area does not provide adequate accessibility for a collection vehicle. 65-feet of unobstructed collection access is recommended. Consider changing collection access angle towards entrance
   Response: See attached revised site plan with corrected dumpster enclosure angle. We have included an Autoturn movement demonstrating the truck movement for garbage pick up.

If you have any questions, I can be reached by phone at 239.984.6524 or directly by email at Sina.Ebrahimi@kimley-horn.com.

Sincerely,



Sina Ebrahimi, P.E.
Project Manager