



September 16, 2022

Lee County Community Development
PO Box 398 (1500 Monroe Street)
Fort Myers, FL 33902

**Culver's – Lehigh Acres
Schedule of Deviations
KHA #045523019**

To whom it may concern:

The proposed project seeks to include the following deviation:

- **LCLDC Sec. 34-2021(d) requires stacking lanes to accommodate ten cars per service lane, with a minimum of five spaces preceding the menu board.**

Deviation: Due to the physical restraints of the existing Culver's restaurant, the proposed side-by-side drive thru allows for 3 spaces per lane preceding the menu boards, as opposed to the 5 required. However, the total stacking preceding the menu board will be increased from 5 spaces to 6 spaces total with the construction of the second drive thru lane.

If you have any additional questions or comments, please feel free to call me at 904-828-3909 or email at Josh.Cockriel@kimley-horn.com.

Sincerely,
KIMLEY-HORN AND ASSOCIATES, INC.

A handwritten signature in black ink, appearing to read "J. Cockriel".

Josh Cockriel, PE