



SOUTH TRAIL FIRE PROTECTION & RESCUE SERVICE DISTRICT

5531 Halifax Ave. Prevention # 239-482-8030
Ft. Myers, FL 33912 Fax # 239-433-2185

Business # 239-433-0080
Fax # 239-433-1941

FIRE FLOW TEST

DATE: 04-28-2022

OUT OF DATE: 04-28-2023

TIME: 08:28

REQUESTED BY: ATWELL LLC

HYDRANT #: 64-0730

HYDRANT (TEST) LOCATION: DANIELS PKWY SECOND EAST OF COMMERCE LAKES

STATIC: 58

RESIDUAL: 32

HYDRANT (FLOW) LOCATION: DANIELS AND COMMERCE LAKES 64-0731

PITOT 1: 18

GPM: 1424

PITOT 2: 18

HYDRANT FLOW AT 20 PSI: 1748

JEFF GILBERT

Name of Person Conducting Test
(Signature)

Notice: The results of this water flow test are an indicator of the available water for fire protection on this date, time, and location, as specified above. The South Trail Fire District makes no expressed or implied guarantees of future water flow for this, or any other location.