ADD2023-00010 Lee County ePlan

OAKVIEW

To Whom it may concern:

As Engineer of Record, I have reviewed the proposed residential equipment pad encroachment scenario and do not believe that this additional area will impede the approved drainage. The equipment pads will abut the homes near the side yard high point and will be staggered between abutting side yards with a ten feet minimum separation. This configuration will provide sufficient area for the lot grading as proposed.

CARL A. BARRACO LICENSE No. 38536 STATE OF FLORIDA PROFESSIONAL ENGINEER

Digitally signed by Carl A. Barraco, P.E.
Date: 2023.01.24 13:21:52 -05'00'

Carl A. Barraco, P.E., FL PE 38536
Barraco and Associates, Inc. 2271 McGregor Blvd., Suite 100
Fort Myers, FL 33901
(239)461-3170 FL CA 7995

This item has been electronically signed and sealed using a SHA-1 authentication code.

Printed copies of this document are not considered signed and sealed and the SHA-1 authentication code must be verified on any electronic copies.