



1520 Royal Palm Square Blvd, Suite 100
Fort Myers, FL 33919
Phone: 239-433-4231
www.tdmcivilengineering.com
Certificate of Authorization # 29086

April 8, 2026

Planning Division
Lee County Department of Community Development
1500 Monroe Street
Fort Myers, FL 33901

RECEIVED
APR 08 2026

COMMUNITY DEVELOPMENT

Reference: Pondella Holdings
CPA2025-00007 (2nd Resubmittal)
Lee County S10-T44S-R24E

Dear Staff:

We are in receipt of your review letter dated April 1, 2026 for the above-referenced project. The following items are submitted for your continued review per this request for additional information:

1. One (1) copy of the revised Sketch and Legal Description, Exhibit M-7;
2. One (1) copy of the revised Narrative of Request, Exhibit M-12;
3. One (1) copy of the Public Information Meeting Summary, Exhibit M-21;
4. One (1) copy of the Historic Resources Impact Analysis, including the Archaeological Sensitivity Zones Map, Exhibit M-14;
5. One (1) copy of the LCU Letter of Availability, Exhibit M-17.

Responses to each individual item/comment are as follows:

Legal Review:

Reviewer: Richard Burris

1. Sketch and Legal Description

The certified legal description(s) and certified sketch of the description for the property subject to the requested change. A metes and bounds legal description must be submitted specifically describing the entire perimeter boundary of the property with accurate bearings and distances for every line. The sketch must be tied to the state plane coordinate system for the Florida West Zone (North America Datum of 1983/1990 Adjustment) with two coordinates, one coordinate being the point of beginning and the other an opposing corner.

Response: Please see the revised Sketch and Legal Description for the correction as requested.

2. The required state plane coordinates have not been provided on the sketch.

Response: Please see the revised Sketch and Legal Description for the correction as requested.

Zoning Review:

Reviewer: Peter Blackwell

3. Historic review: Applicant needs to provide a letter from the Florida Division of Historic Resources listing any historic resources within the subject property.

Response: Please see the revised Historic Resources Analysis, including a map and exhibits from the Florida Division of Historic Resources as requested.

4. Historic: The applicant needs to provide a map of the property showing the Archeological Sensitivity Zones.

Response: Please see the attached Archeological Sensitivity Zones Map as requested. Note this is combined with the Exhibit M-14 Historic Resources Analysis.

Planning Review:

Reviewer: Lindsey Karczewski

5. Exhibit M-21 reads that the applicant is requesting to amend Map 1-C Mixed Use Overlay (MUO). Revise for consistency of application materials.

Response: Please see the revised Exhibit M-21 for the correction as requested. All application materials should be consistent.

6. Per the application requirements on application page 3, include the request letter to LCU within the next submittal.

Response: Please see the attached LCU Letter of Availability, including request form, as requested.

7. Include an analysis of Objective 30.4 and Policy 30.4.2 to support the request.

Response: Please see the revised Lee Plan Analysis for the information requested.


This should allow for continued review and a finding of sufficiency of this Comprehensive Plan Amendment request. Your time and attention to this matter is appreciated. Should County staff require additional information or have any questions regarding this submittal, feel free to call this office.

Sincerely,

TDM CONSULTING, INC.



Veronica Martin
Senior Planner



DESCRIPTION TO ACCOMPANY SKETCH
EXHIBIT "A"

(PROPOSED)
**A PARCEL OF LAND LYING IN
THE N.E. 1/4 OF SECTION 10,
TOWNSHIP 44 SOUTH, RANGE 24 EAST,
PUBLIC RECORDS OF LEE COUNTY, FLORIDA**

DESCRIPTION:

A PLOT OR PARCEL OF LAND LYING IN A PORTION OF LOTS 1, 2, 3, AND 4, BLOCK "A", PONDELLA SHORES, AS RECORDED IN PLAT BOOK 10, PAGE 12, OF THE PUBLIC RECORDS OF LEE COUNTY, FLORIDA, AND A PORTION OF THE NORTHEAST QUARTER (1/4) OF SECTION 10, TOWNSHIP 44 SOUTH, RANGE 24 EAST, PUBLIC RECORDS OF LEE COUNTY, FLORIDA, SAID PLOT OR PARCEL OF LAND BEING MORE PARTICULARLY DESCRIBED AS FOLLOWS:

COMMENCING AT THE NORTHEAST CORNER OF SAID SECTION 10; THENCE RUN N.89°56'13"W. ALONG THE NORTH LINE OF SAID SECTION 10, FOR 416.62 FEET; THENCE RUN S.01°02'20"W. TO A POINT ALONG THE SOUTH LINE OF PONDELLA ROAD, FOR 87.05 FEET, FOR A POINT OF BEGINNING; THENCE CONTINUE S.01°02'20"W. TO A POINT ALONG THE NORTH RIGHT OF WAY LINE OF BLAIR STREET (50 FEET WIDE), FOR 247.95 FEET; THENCE RUN N.89°56'13"W. ALONG SAID NORTH RIGHT OF WAY LINE FOR 239.58 FEET; THENCE RUN S.01°33'19"W., FOR 326.92 FEET; THENCE RUN S.89°55'11"W. TO A POINT ALONG THE EAST LINE OF THE AFORESAID PONDELLA SHORES, FOR 332.91 FEET; THENCE RUN N.01°37'32"E. ALONG SAID EAST LINE, TO THE COMMON LOT CORNER BETWEEN LOTS 4 AND 5 OF SAID PONDELLA SHORES, FOR 472.83 FEET; THENCE RUN N.89°56'13"W. TO A POINT ALONG THE EAST RIGHT OF WAY LINE OF BETMAR BOULEVARD (50 FEET WIDE), FOR 326.64 FEET; THENCE RUN N.01°37'32"E. ALONG SAID EAST RIGHT OF WAY TO A POINT ALONG THE AFORESAID SOUTH RIGHT OF WAY LINE OF PONDELLA ROAD, FOR 98.11 FEET; THENCE RUN S.89°48'52"E. ALONG SAID SOUTH RIGHT OF WAY, FOR 566.34 FEET, TO A POINT OF CURVATURE; THENCE RUN ALONG THE ARC OF A CURVE, TO THE LEFT, FOR 330.03 FEET, SAID CURVE HAVING THE FOLLOWING ELEMENTS, A RADIUS OF 8,064.50 FEET, A CENTRAL DELTA ANGLE OF 02°20'41", A CHORD THAT BEARS N.89°00'50"E., AND A CHORD DISTANCE OF 330.00 FEET, TO THE POINT OF BEGINNING. CONTAINING 279,532 SQUARE FEET OR 6.42 ACRES, MORE OR LESS.

BEARINGS ARE BASED ON THE AFORESAID NORTH LINE OF SECTION 10, TOWNSHIP 44 SOUTH, RANGE 24 EAST, AS BEING N.89°56'13"W.

PHILLIP M. MOULD
PROFESSIONAL SURVEYOR AND MAPPER, LS6515
FEBRUARY 13, 2025



1520 Royal Palm Square Blvd, Suite 100
Fort Myers, FL 33919
Phone: 239-433-4231
www.tdmcivilengineering.com
Certificate of Authorization # 29086

Pondella Holdings
Lee Plan Analysis – Exhibit M12
Revised 4-7-2026

Lee Plan Compliance:

***Policy 1.1.3:** The Central Urban future land use category can best be characterized as the “urban core” of the County. These areas are already the most heavily settled and have, or will have, the greatest range and highest levels of public services. Residential, commercial, public and quasipublic, and limited light industrial land uses will continue to predominate in the Central Urban future land use category. Future development in this category is encouraged to be mixed use, as described in Objective 11.1, where appropriate. The standard density range is from four dwelling units per acre (4 du/acre) to ten dwelling units per acre (10 du/acre), with a maximum total density of fifteen dwelling units per acre (15 du/acre). The maximum total density may be increased to twenty dwelling units per acre (20 du/acre) utilizing Greater Pine Island Transfer of Development Units.*

The Central Urban future land use category is described as the urban core of the county with the greatest range and highest levels of public services. Amending Lee Plan Map 4-B Lee County Utilities Future Sewer Service Area Map increases the level of public services available to the community. At this time, there's a small enclave of properties that lie outside of LCU's sewer franchise area or any other certified franchise area. Amending the Lee Plan Map 4-B is consistent with **Lee Plan Policy 1.1.3.**

***Objective 2.1: Development Location** promotes continuous and compact growth patterns through the rezoning process to contain urban sprawl, minimize energy costs, conserve land, water and natural resources, minimize the cost of services, and prevent development patterns where large tracts of land are by-passed in favor of development more distant from services and existing communities.*

***Policy 2.1.1:** Most residential, commercial, industrial, and public development is expected to occur within the designated future urban areas on the Future Land Use Map through the assignment of very low densities to the non-urban categories.*

***Policy 2.1.2:** New land uses will be permitted only if they are consistent with the Future Land Use Map and the goals, objectives, policies, and standards of this plan.*

***Objective 2.2: Development Timing.** Direct new growth to those portions of the future urban areas where adequate public facilities exist or are assured and where compact and contiguous development patterns can be created.*

The subject property is considered an infill parcel with existing development on all sides. As previously noted, the subject property is within a small enclave of land that is not serviced by a certified franchise area; however, LCU's future sewer service area is located to the east, south, and west of the property. The property has a wide range of urban services available, with the exception of sanitary sewer. Development of this property promotes compact and contiguous growth patterns in future urban areas where public facilities exist and are adequate to serve future developments. Amending Lee Plan Map 4-B Lee County Utilities Future Sewer Service Area Map increases the level of public services available to the community. Amending Lee Plan Map 4-B is consistent with **Lee Plan Objectives 2.1: Development Location and 2.2: Development Timing, and Policies 2.1.1 and 2.1.2.**

Objective 4.1: Water, Sewer, and Environmental Standards. *Consider water, sewer, and environmental standards during the rezoning process. Ensure the standards are met prior to issuing a local development order.*

Standard 4.1.1: Water.

- 1. Any new residential development that exceeds 2.5 dwelling units per gross acre, and any new single commercial or industrial development in excess of 30,000 square feet of gross leasable (floor) area per parcel, must connect to a public water system (or a "community" water system as that is defined by Fla. Admin. Code R. 62-550).*
- 2. If the proposed development lies within the boundaries of a water utility's certificated or franchised service area, or Lee County Utilities' future potable water service area (see Map 4- A), then the development must be connected to that utility.*
- 3. The developer must provide proof that the prior commitments of the water utility, plus the projected need of the developer, do not exceed the supply and facility capacity of the utility.*

Lee County Utilities (LCU) provided a Letter of Availability confirming that potable water lines are in operation adjacent to the subject property and that LCU presently has sufficient capacity to provide potable water service as estimated. LCU also stated that there are no reuse mains in the vicinity. This is consistent with **Lee Plan Standard 4.1.1: Water.**

Standard 4.1.2: Sewer.

- 1. Any new residential development that exceeds 2.5 dwelling units per gross acre, and any new single commercial or industrial development that generates more than 5,000 gallons of sewage per day, must connect to a sanitary sewer system.*
- 2. If the proposed development exceeds the thresholds listed above and lies within the boundaries of a sewer utility's certificated or franchised service area, or Lee County Utilities' future sanitary sewer service area (see Map 4-B), and that utility has sufficient capacity to provide minimum service to the development, then the development must connect to that sewer utility if there is existing infrastructure adequate to accept the effluents of the development within 1/4 mile from any part of the development.*
- 3. If there is not sufficient capacity nor adequate infrastructure within 1/4 mile of the development, the developer must provide proof in the form of a clearly stated rejection of service.*
- 4. If a new development is located in a certificated or franchised service area, or Lee County Utilities' future sanitary sewer service area (see Map 4-B), and the utility cannot provide the*

service, or cannot provide the service except at a clearly unreasonable cost to the developer, the developer may establish on a temporary basis a self-provided sanitary sewer facility for the development, to be abated when the utility extends service to the site. The developer may also petition the appropriate regulatory agency to contract the service area of the utility in order that another utility may be invited to provide the service.

5. If a development lies outside any service area as described above, the developer may:

- request that the service area of Lee County Utilities or an adjacent sewer utility be expanded to incorporate the property;*
- establish a self-provided sanitary sewer system for the development;*
- develop at an intensity that does not require sanitary sewer service; or*
- if no more than 5000 gallons of effluent per day per parcel is produced, an individual sewage disposal system per Fla. Admin. Code R. 64E-6 may be utilized, contingent on approval by all relevant authorities.*

6. Lee County Utilities may provide sanitary sewer service to properties not located within the future sewer service area when such sanitary sewer service is found to benefit public health, safety, and welfare, including protection of Lee County's natural resources.

The subject property lies outside of Lee County Utilities services area; however, the applicant is requesting to amend Lee Plan Map 4-B, Lee County Utilities Future Sewer Service Area Map, to permit LCU to provide sanitary sewer service to the site. LCU provided a Letter of Availability stating that sanitary sewer lines are currently not available adjacent to the site. The applicant is aware that developer-funded extensions may be required. The purpose of this application is to provide sanitary sewer to the future development of the subject property. The proposed amendment is consistent with **Lee Plan Standard 4.1.2: Sewer, subsection 5.**

Standard 4.1.3: Reuse.

1. Any development that requires a development order, on a property that is adjacent to public reuse infrastructure with sufficient capacity, must connect to the reuse system for irrigation needs.

2. Any new development that, at build-out, has an anticipated irrigation demand of 50,000 gallons per day, or more, using the Blaney-Criddle method, must connect to a public reuse system for irrigation needs when sufficient capacity and adequate infrastructure is within ¼ mile from any part of the development.

3. If there is not sufficient capacity or adequate infrastructure within ¼ mile of the development, the developer must provide proof in the form of a clearly stated rejection of service.

4. If a development has been rejected for reuse service, the proposed source of irrigation water must be identified consistent with Policy 61.1.6.

Lee County Utilities (LCU) provided a letter stating that there aren't any reuse mains in the vicinity of the subject property. The applicant will be required to provide the anticipated irrigation demand calculations at time of Development Order permitting and will be required to provide the necessary infrastructure at that time or provide the source of irrigation water (wells) consistent with Lee Plan Policy 61.1.6. This is consistent with **Lee Plan Policy 4.1.3.**

Objective 5.1: *All development approvals for residential, commercial, and industrial land uses must be consistent with the following policies, the general standards under Goal 4, and other provisions of this plan.*

Amending Lee Plan Map 4-B to add the subject property to Lee County Utilities Future Sewer Service Area Map provides additional urban services to the land in the Central Urban future land use category. This is consistent with Goal 4 of the Lee Plan and **Objective 5.1**.

Objective 6.1: *Development approvals for commercial land uses must be consistent with the following policies, the general standards under Goal 4, and other provisions of this plan.*

The subject property is located along a commercial corridor as identified by LDC Sec. 33-1566, the North Fort Myers Community Plan. As such, commercial development is encouraged at this location. Amending Lee Plan Map 4-B to add the subject property to Lee County Utilities Future Sewer Service Area Map provides additional urban services to the area. This is consistent with Goal 4 of the Lee Plan and **Objective 6.1**.

Policy 11.2.1: *The Mixed Use Overlay identifies locations where mixed use development will have a positive impact on transportation facilities through increased transit service, internal trip capture, and reduced travel distance. Requests to expand the Mixed Use Overlay will be evaluated based on all of the following criteria:*

- 1. Located within the extended pedestrian shed of established transit routes; and,*
- 2. Distinct pedestrian and automobile connections to adjacent uses can be achieved without accessing arterial roadways; and,*
- 3. Located within the Intensive Development, Central Urban, or Urban Community future land use categories;*
- 4. Availability of adequate public facilities and infrastructure; and*
- 5. Will not intrude into predominately single-family residential neighborhoods.*

The subject property is currently located in the Mixed-Use Overlay per Lee Plan Map 1-C. Once of the requirements is the availability of public facilities and infrastructure. Amending Lee Plan Map 4-B to add the subject property to LCU's Future Sewer Service Area Map is consistent with the Mixed-Use Over, **Policy 11.2.1**.

Objective 17.3: Public Input. *To provide opportunities for public input as part of the comprehensive plan and land development code amendment process.*

Policy 17.3.2: *One public information meeting is required for privately-initiated applications that propose a text change within a community plan or revises a map designation within a community plan area boundary. The meeting must be conducted before the application can be found complete.*

Policy 17.3.4: *For required public information meetings, the applicant must provide the following:*

- Adequate meeting space to accommodate projected attendance and security measures (as needed).*
- Advance notice of the meeting in a publication of local distribution provided at least ten calendar days prior to the meeting, unless otherwise specified herein.*
- At the meeting, a general overview of the text or map amendment and effect thereof.*

- *After the meeting, a meeting summary document submitted to the County that contains the following information: the date, time, and location of the meeting; a list of attendees; a summary of the concerns or issues that were raised at the meeting; and the applicant's response to any issues that were raised.*

A Public Information Meeting was held on March 3, 2026 in the North Fort Myers community planning area as required by LDC Sec. 33-1532. The proposed comprehensive plan amendment and conventional rezoning applications were presented to the public. The public information meeting summary, notice of meeting, and sign-in sheet are included with the application. This is consistent with **Lee Plan Policies 17.3.4 and 17.3.5.**

Goal 30: North Fort Myers Community Plan. *Improve the livability and economic vitality in the North Fort Myers Community Plan area by: promoting compact, mixed use development in the form of town and neighborhood centers; attracting appropriate investment to revitalize older neighborhoods and commercial corridors; stabilizing and enhancing, existing neighborhoods; and preserving natural resources.*

Objective 30.4: Community Facilities & Services. *To provide community facilities and services within the Town Centers, Neighborhood Centers and Corridor Overlay Districts.*

Policy 30.4.2: *Support the concept of a single source of sewage service to the North Fort Myers Community Plan area.*

The goal of the North Fort Myers community plan is to improve the livability and economic vitality in the area by promoting compact, mixed use development; attracting appropriate investment to revitalize older neighborhoods and commercial corridors; stabilizing and enhancing existing neighborhoods; and preserving natural resources. The subject property is located in the North Fort Myers planning community area along a designated corridor overlay - Pondella Road. As previously stated, the applicant assembled multiple vacant lots along Pondella Road, creating a site for future development. The site can be viewed as an infill development since the majority of the land on all four sides is currently developed with a mix of residential and commercial uses. Adding the subject property to Lee County Utilities (LCU) future sewer service area is consistent with Lee Plan Objective 30.4, which promotes community facilities and services within corridor overlay districts and Policy 30.4.2, which promotes the concept of a single source of sewage service to the North Fort Myers Community Plan Area. Amending Lee Plan Map 4-B, LCU's Future Sewer Service Area Map to include the subject property encourages future development and provides a necessary service to the community. This is consistent with **Lee Plan Goal 30, Objective 30.4 and Policy 30.4.2.**

Goal 56: Sanitary Sewer Infrastructure. *In partnership with franchised/certificated utilities providers, provide sanitary sewer service and wastewater treatment and disposal throughout Lee County.*

Objective 56.1: *The County will ensure the provision of acceptable levels of sanitary sewer service throughout the future urban areas of the unincorporated County, either directly by Lee County Utilities or a utility authority, or indirectly through franchised utility companies.*

The subject property is located in a future urban area of Lee County – Central Urban. According to the 2024 Concurrency Report, LCU has adequate facilities to serve the proposed development's estimated 6,420 GPD. As previously noted, the subject property is located within a small enclave

of land that is not located within a sewer franchise area; however, the properties to the east, south, and west are within the LCU's sewer franchise area. The Applicant is requesting to amend Lee Plan Map 4-B to expand LCU's Future Sewer Service Area, which is consistent with Lee Plan Goal 56 and Objective 56.1.

***Policy 101.1.1:** Require that development within the Coastal High Hazard Area be compatible with natural systems, such as, water retention and purification, wildlife habitat, primary productivity, and defense against coastal flooding.*

***Policy 101.3.2:** Restrict development in the Coastal High Hazard Area to uplands except as needed for the provision of public facilities.*

***Policy 101.3.4:** Encourage new residential development, as required by the LDC, to provide continuing information to residents concerning hurricane evacuation and shelters.*

A local development order and SFWMD ERP will be required for the development. The applicant must comply with the rules and regulations at that time, including LDC Article XI – Hurricane Preparedness and LDC Sec. 2-485 Impact Mitigation. This is consistent with **Lee Plan Policies 101.1.1, 101.3.2 and 101.3.4.**



**43 Barkley Circle, Suite 200
Fort Myers, FL 33907
Phone 239-433-4231 Fax 239-433-9632
www.tdmcivilengineering.com
Certificate of Authorization # 29086**

**Planning Community Requirements – Exhibit M21
Revised 4-7-2026**

The Applicant, Pondella Holdings, LLC, is requesting to amend Lee Plan Map 4-B, the Lee County Utilities Future Sewer Service Area Map. The project site is in the North Fort Myers planning community area. Per Lee Plan Policy 17.3.2, one public information meeting is required for privately-initiated applications that propose a text change within a community plan or revises a map designation within a community plan area boundary. A Summary of the Public Informational Meeting is provided below.

A Public Information Meeting was held at the North Fort Myers Recreation Center on March 3, 2026 at 6:00 p.m. The Notice of Meeting was published in the News-Press and two (2) meeting signs were posted along the property frontage/Pondella Road right-of-way, as required by the North Fort Myers Community Planning Panel. A copy of the News-Press Ad and Sign-in Sheet are included with this summary.

The presentation included two (2) application requests: (1) to add the site to Lee Plan Map 4-B: Lee County Utilities Future Sewer Service Area Map; and (2) to rezone the subject property from RS-1, C-1, C-1A, and CT to CT for a consistent zoning district in order to develop the property. The site is in the Mixed Use Overlay and the property owner intends to develop the site with multi-family residential uses with a small commercial component. With current density calculations, they can build approximately 60 dwelling units or up to 90 dwelling units if they decide to utilize bonus density. The comp plan amendment and rezoning are the first phase. If approved, the application will apply for a development order. Engineering plans haven't been started yet.

- Address: 333 Pondella Road
- Site: 6.42 acres
- FLU: Central Urban
- Surrounding zoning and uses
- Max. # dwelling units: 60 or 90 with bonus density

Questions and Comments:

1. There's already too much traffic on Pondella. This will only increase traffic.
A traffic impact study will be completed at time of DO permitting.
2. Where will the driveway be located?
At this time, plans are to have the site accessed directly from Pondella.
3. What about the side streets – Betmar Blvd?

The plans don't include access from the side streets/local roads; however, that's up to LCDOT and fire.

4. Our properties flooded the last 3 storms. This development will only make that worse.
The applicant will be required to get an ERP from SFWMD at time of DO permitting. The site will require stormwater management on site along with a berm around the property. (The engineers on the NFM planning panel explained to the public how the ERP worked to manage flooding.)
5. How many units?
A max of approximately 60 dwelling units with base density and up to approximately 90 units with bonus density.
6. What is bonus density and are they asking for it?
Bonus density permits the applicant to build more units with a cash contribution or affordable housing program. The applicant hasn't determined if bonus density will be utilized at this time.
7. How much of the land is zoned RS-1?
Approximately 1.5 acres in the NE corner of the site.
8. What uses are permitted in the CT zoning district?
Mostly that uses that support commercial tourism, including, but limited to: hotels/motels, business services, retail, medical offices, restaurants, and multi-family. The NFM members explained that the majority of the site was already zoned CT or C-1 and C-1A, which already permit the uses proposed.

The public was advised that TDM (engineer), the architect, and landscape architect will be required to make another presentation to the NFM community planning area for the development order and full plans will be provided at that time. They were also advised that if they have objections to the rezoning, they can attend the HEX hearing and voice their concerns at that time. The members of the North Fort Myers Community Planning Panel were supportive of the development and helped explain several concerns from the public regarding the use, density, drainage and traffic.



1520 Royal Palm Square Blvd, Suite 100

Fort Myers, FL 33919

Phone: 239-433-4231

www.tdmcivilengineering.com

Certificate of Authorization # 29086


Historic Resources Impact Analysis – Exhibit M14

Revised 4-8-2026

Analysis

The Florida Division of Historic Resources provided a map identifying a single Florida Structure on the subject property. The site address is listed as 363 Pondella Road, which was a single lot prior to the lot combination. Additional information on the Cultural Resource Roster states the item is a Frame Vernacular. Archaeological Consultants, Inc. provided the survey information in 1992. Since that time, the structure has been removed from the site (by one of the previous property owners). Looking at the Aerials provided by the Property Appraiser's Office, the structure was removed prior to 1998 by the property owner.

The historic resource (Florida Structure) is no longer located on the subject property so the site is unencumbered. In addition, amending Lee Plan Map 4-B Lee County Utilities Future Sewer Service Area Map to include the subject property will have no impacts on the Historic or Archaeological Sensitivity level of the property. The Archaeological Sensitivity of the subject property is unrelated to the amendment request.



Legend

- FloridaSites
- FloridaStructures
- HistoricalBridges
- HistoricalCemeteries
- ResourceGroups
- FieldSurveys



AR=0
SS=1
CM=0
RG=0
BR=0
Total=1

Cultural Resource Roster

SiteID	Type	Site Name	Address	Additional Info	SHPO Eval	NR Status
LL01604	SS	363 PONDELLA RD	363 PONDELLA RD, FT MYERS	Frame Vernacular		



Total=1

Manuscript Roster

MS#	Title	Publication Information	Year
3051	A Cultural Resources Survey of a Portion of Pondella Road from Joerin Avenue to Betmar Blvd., Lee County, Florida	Archaeological Consultants, Inc., Sarasota. Submitted to Ink Engineering, Inc., North Fort Myers.	1992

PONDELLA HOLDINGS
ARCHAEOLOGICAL SENSITIVITY ZONES MAP

EXHIBIT M-14





Lee County
Southwest Florida

Board of County Commissioners

Kevin Ruane
District One

Cecil L. Pendergrass
District Two

David Mulicka
District Three

Brian Hamman
District Four

Trish Petrosky
District Five

Dave Harner, II
County Manager

Richard Wm. Wesch
County Attorney

Donna Marie Collins
County Hearing
Examiner

February 27, 2026

Via E-Mail

Veronica Martin
TDM Consulting, Inc.
1520 Royal Palm Square Blvd, Suite 100
Fort Myers, FL 33919

RE: Potable Water and Wastewater Availability
333 Pondella Road
333 Pondella Rd, North Fort Myers, FL 33903
STRAP # 10-44-24-L2-00018.0010

To whom this may concern:

The subject property is located within Lee County Utilities Future Service Area as depicted on Map 4A of the Lee County Comprehensive Land Use Plan for potable water. The subject property is not located within the Lee County Utilities Future Service Area as depicted on Map 4B of the Lee County Comprehensive Land Use Plan for Wastewater. Potable water lines are in operation adjacent to the property mentioned above. However, to provide service to the subject parcels, developer funded system enhancements such as line extensions may be required.

Your firm has indicated that this project will consist of a multi-family development with 120 units and a 4,500 sq. ft. retail complex with an estimated flow demand of approximately 19,650 gallons per day. Lee County Utilities presently has sufficient capacity to provide potable water service as estimated above.

Availability of potable water and sanitary sewer service is contingent upon final acceptance of the infrastructure to be constructed by the developer. Upon completion and final acceptance of this project, potable water service will be provided through our North Lee County Water Treatment Plant.

Sanitary sewer and Reuse services from Lee County Utilities are currently not available adjacent to this property.

Prior to beginning design work on this project, please meet with LCU Staff to determine the best point of connection and discuss requirements for construction. This letter should not be construed as a commitment to serve, but only as to the availability of service. Lee County Utilities will commit to serve only upon receipt of all appropriate connection fees, a signed request for service and/or an executed service agreement, and the approval of all State and local regulatory agencies.

Further, this letter of availability of potable water and sanitary sewer service is to be utilized for rezoning and comprehensive plan amendment purposes only. Individual letters of availability will be required for the purpose of obtaining building permits.

Sincerely,

Aixa Cruz

LEE COUNTY UTILITIES
Utilities Plan Reviewer, 239-533-8531



LEE COUNTY UTILITIES
REQUEST FOR LETTERS OF AVAILABILITY

DATE: FEBRUARY 26, 2026

TO: DCAP STAFF

Lcudcap@leegov.com

FROM: VERONICA MARTIN

FIRM: TDM CONSULTING, INC.

ADDRESS: 1520 ROYAL PALM SQUARE BLVD, SUITE 100

ADDRESS: FORT MYERS, FL 33919 -

PHONE#: (239)433-4231 FAX: () -

E-MAIL ADDRESS: VMARTIN@TDMCONSULTING.COM

PROJECT NAME: 333 PONDELLA ROAD

PREVIOUS PROJECT NAME(S):

10-44-24-L2-00018.0010

STRAP NUMBER(S):

PRIOR STRAP NUMBER(S) (IF ANY):

333 PONDELLA ROAD, NORTH FORT MYERS, FL 33903

LOCATION/SITE ADDRESS:

PURPOSE OF LETTER:

- ☐ DEVELOPMENT ORDER SUBMITTAL ☐ FINANCING ☐ EFFLUENT REUSE
☐ PERMITTING OF SURFACE WATER MANAGEMENT (SOUTH FLORIDA WATER MANAGEMENT DISTRICT)
☒ OTHER: (PLEASE SPECIFY) REZONING APPLICATION AND COMP PLAN AMENDMENT

PLANNED USE:

- ☒ COMMERCIAL ☐ INDUSTRIAL ☒ RESIDENTIAL - (☐ SINGLE-FAMILY ☒ MULTI-FAMILY)
☐ OTHER: (PLEASE SPECIFY) _____

PLANNED # OF COMMERCIAL/INDUSTRIAL BUILDINGS: 1 TOTAL SQUARE FOOTAGE 4,500 SF

RESIDENTIAL UNITS: SINGLE-FAMILY: _____ MULTI-FAMILY: 120

AVERAGE ESTIMATED DAILY FLOW (GPD): 19,650 (☒ WATER ☒ WASTE-WATER) (GPD): 19,650 ☒ REUSE

PLEASE SHOW CALCULATION USED TO DETERMINE AVERAGE ESTIMATED DAILY FLOW (GPD) PER CRITERIA SET FORTH IN LEE COUNTY UTILITIES DESIGN MANUAL: _____

Multi Family

120 Units X 160 GPD/Unit = 19,200 GPD

Retail

4,500 SF X 0.10 GDP/SF = 450 GPD

Total Flow for both Water and Sewer = 19,650 GPD

Please e-mail the completed form to Lcudcap@leegov.com.

If you should have any questions or require assistance, please feel free to call our office at (239) 533-8531.

